

MUNICIPAL CORPORATION OF DELHI

(Office of the Sanitation Superintendent)
Department of Environment management services
Karol Bagh Zone

No. 5494

Date: 27.10.2022

SCHOOL SANITATION CERTIFICATE

Name of the School : Salwan Public School

Location : Pt. Girdhari Lal Salwan Marg,
Rajinder Nagar, New Delhi-110060

Date of Inspection : 27.10.2022

No. of Students : Boys 1641 Girls 1020 Total 2661

That the accommodation Provide : Neat & Clean

The clean rooms calculated : 70 Rooms

Floor space in sufficient or not : Sufficient

That the Class rooms are well
Lighted or Not : Well Lighted

That the drinking water is wholesome
or not : Wholesome

That the latrina arrangement is
adequate or not : Adequate

REMARKS :-

The School is found neat and clean and fit from sanitation point of view. Therefore, NOC is granted.



Sanitation Superintendent
Karol Bagh Zone
Sanitation Superintendent
DEMS/Karol Bagh Zone
NORTH DMC

STOP CORONA

WEAR MASK

MAINTAIN SOCIAL DISTANCE



**DELHI JAL BOARD: GNCTD
CENTRAL LABORATORY WTP WAZIRABAD, DELHI-54**



TEST REPORT

Sample ID	Ref.No. D.J.B/CWA/Wzd./2022/paid-157-160		
-152Location /Address of Sample	Salwan Public School, Girdharilal Salwan Marg, Rajender Nagar Delhi-60		
Name of Work	--		
Reference No.	SPS/3102/2022	Ref. Letter Date	27.09.2022
Challan No.	200	Challan Date	27.09.2022
Sample Collection date	03.10.2022	Analysis date	03.10.2022
Any other Information	--	Reporting date	06.10.2022

TEST RESULTS

S.N.	Parameters	Unit	As per the IS 10500		Inlet	R.O	R.O in Ground Complex
			Desirable limit	Permissible limit			
1	Turbidity	NTU	1	5	1.47	0.92	0.87
2	pH Value	--	6.5-8.5	No relaxation	7.47	7.21	7.23
3	Colour	Pt-Co	5	15	Clear	Clear	Clear
4	Odour	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable
5	Electrical Conductivity	µs/cm	-	-	280	80	40
6	Total Dissolved Solids	Mg/l	500	2000	140	40	20
7	Total Alkalinity as CaCO ₃	Mg/l	200	600	88	24	06
8	Total Hardness as CaCO ₃	Mg/l	200	600	108	20	10
9	Calcium as Ca	Mg/l	75	200	26.4	4.8	2.4
10	Magnesium as Mg	Mg/l	30	100	10.08	1.92	0.96
11	Ammonical-Nitrogen	Mg/l	NIL	0.5	ND	ND	ND
12	Nitrate	Mg/l	--	45	4.3	1.7	0.9
13	Chlorides as Cl	Mg/l	250	1000	24	10	04
14	Fluoride as F	Mg/l	1.0	1.5	0.31	0.17	0.14
15	Sulphate as SO ₄	Mg/l	200	400	21.7	2.3	1.8
16	T. Iron	Mg/l	--	1.0	0.10	0.04	0.04
17	Residual Chlorine	Mg/l	0.2	1.0	1.5	ND	ND
18	COLIFORM COUNT AT 37 ^o C	MPN/100 ml	Absent	--	0	0	0

.....End of Report.....

Remarks : On the basis of tested parameters the water sample confirm drinking water Specification IS-10500 and is fit for drinking purpose.

[Signature]
ACWA
Asst. Chief Water Analyst
Central Lab. of D.J.B. of Delhi
WTP, Wazirabad

[Signature]
CHEMIST

[Signature]
A/CHEMIST